



State of Wisconsin
Jim Doyle, Governor

Department of Agriculture, Trade and Consumer Protection
Rod Nilsestuen, Secretary

March 9, 2007

Larry Gobrecht
Double GG Protective Coatings
105 Miner Way
Shullsburg, WI 53586

Dear Mr. Gobrecht:

Thank you for supplying information on the product Polyeuro 5502. You have asked if this product could be applied to walls and ceilings in milkhouses and food processing rooms in Wisconsin. After a review of the letter from Ultimate Linings to USDA, it is clear that after curing, this product produces a waterproof and non-toxic surface and is acceptable in a food production environment.

Although the material is acceptable, proper application will include providing a smooth and light colored finish to comply with requirements in administrative rules for food processing rooms.

If you have any questions concerning my comments I can be reached by phone at 608/224-4732.

Sincerely,

Glenn A. Goldschmidt, RS
Equipment & Process Specialist

Cc: File